

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3240-1496:132 Page 1 of 1

CATEGORY: Duct Smoke Detector Housing/Base

LISTEE: Firecom Inc., 39-27 59th Street, Woodside, NY 11377
Contact: Howard Kogen (718) 899-6100

DESIGN: Models F600-2W-N, F600-2W-P, F900-AR-N, F900-AR-P duct detectors. Models F600-2W-N, F600-2W-P are two-wire duct detectors.

F600 and F900 Series utilizes Models F600-250 (CSFM Listing No. 7271-1496:124) or F600-350 (CSFM Listings No. 7272-1496:121) or F900-550 (CSFM Listing No. 7271-1496:120) or F900-650 (CSFM Listing No. 7272-1496:123) detectors.

Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as duct detectors for use with separately listed compatible fire alarm control units when installed in HVAC systems with air velocity between 500 and 3000 ft./min.

XLF: 3240-1004:100

03-11-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 22, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager